

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Copy for:

RESOLUTION NO. G-1390

Orig. and Copy

to Secretary

R E S O L U T I O N

UTILITIES DIVISION

BRANCH/SECTION: GAS

DATE: October 3, 1967

Director

Numerical File

✓ Alphabetical File

Accounting Officer

SUBJECT: Order Authorizing Deviation from a Portion of
Section 5.e.1. of General Order No. 94-A

WHEREAS: Del Norte Gas Company, by letter dated September 7, 1967, having requested authority under Section 1 of General Order No. 94-A to deviate from the specified procedure required by Section 5.e.1. of this order with respect to the 20-year inspection of a liquid hydrocarbon storage vessel, as outlined in said letter, and

WHEREAS: The utility has requested the use of the non-destructive reflectoscope method when examining for internal corrosion during the inspection of its liquid hydrocarbon vessel located in Crescent City, California, and

WHEREAS: If the results of any such test indicate that the vessel is in a defective or hazardous condition, it must be removed from service, repaired and tested in accordance with General Order No. 94-A before it is again placed in service, and

WHEREAS: Such deviation will relieve the utility from unnecessary expenses, hardship, disruption of service, and, good cause appearing,

IT IS ORDERED that authority be granted under Section 768 of the Public Utilities Code for California-Pacific Utilities Company, to carry out the inspection procedure as outlined in its letter of September 7, 1967, under the condition stated herein.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular conference of the Public Utilities Commission of the State of California, held on the 3rd day of October, 1967, the following Commissioners voting favorably thereon:

PETER E. MITCHELL


President

A. W. GATOV

WILLIAM SYMONS, JR.

FRED P. MORRISSEY

Commissioners



Secretary