

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

✓ M

Copy for:

RESOLUTION NO. G-1817

Orig. and Copy
to Secretary

UTILITIES DIVISION
BRANCH/SECTION: Gas
DATE: September 30, 1975

RESOLUTION

Director
Numerical File
Alphabetical File
Accounting Officer

SUBJECT: Request to Provide Additional Natural Gas Service by Pacific Gas and Electric Company

WHEREAS: PACIFIC GAS AND ELECTRIC COMPANY, by Advice Letter No. 749-G, filed August 26, 1975, having requested Commission approval under Decision No. 83819 to provide additional interruptible gas service to One Market Plaza for the new Southern Pacific office building complex in San Francisco, and

WHEREAS: The customer states that the amount of additional gas needed is an average of 365 Mcfd on a year-round basis with a peak demand of 53 Mcfh, and

WHEREAS: The customer will use this additional gas for boiler fuel, and currently has standby fuel storage capacity for a five-day supply of No. 2 fuel oil, and

WHEREAS: Under present and expected natural gas supply conditions, an office building should have a 30-day standby fuel storage capacity, and

WHEREAS: To require the customer to install adequate fuel standby facilities could delay the occupancy and use of the building appreciably, and

WHEREAS: Installation of this new boiler system will result in the discontinuation of an old inefficient boiler system rates at 92 Mcfd, and

WHEREAS: The customer's request for service was pending prior to Decision No. 83819, and

WHEREAS: The buildings were constructed with the assumption that gas service would be available and thus adequate standby fuel storage capacity was not built, therefore; good cause appearing,

IT IS ORDERED that authority be granted under the provisions of Decision No. 83819 for Pacific Gas and Electric Company to supply the requested interruptible natural gas service to One Market Plaza effective September 25, 1975, for a period of time expiring October 1, 1976, and that the customer be notified that they will be expected to install adequate alternate fuel storage by the end of the time herewith authorized.

IT IS FURTHER ORDERED that the above advice letter and application be marked to show that they were authorized conditionally, under Resolution of the Public Utilities Commission of the State of California No. G-1817.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular conference of the Public Utilities Commission of the State of California, held on the 30th day of September, 1975, the following Commissioners voting favorably thereon: