



EXISTING ROW

220kV DC TOWER

FACING EAST



220kV SC TOWER



ROW
EDGE

ROW
EDGE

70-80 ft

60-80 ft


65-80 ft

230-240 ft

FUTURE ROW

FACING EAST

220kV DC TOWER



500kV DC DHT TOWER

22.5 ft

104 ft

147-249.5 ft

ROW
EDGE

ROW
EDGE

50-95 ft

75-95 ft

40-80 ft

230-240 ft

Source: SCE, 2007d.

NOTE:
 This drawing represents potential changes
 between existing and future ROW cross sections.



Figure 2.2-33

**Segment 8 ROW Cross-Section
 (S8A MP 8.1 to S8A MP 9.0)**