



Overall Visual Change: high. With high visual contrast, high dominance, and high view blockage/impairment of the ridgeline and background mountains, the overall visual change would be high; and combined with the moderate-to-high overall visual sensitivity of the visual setting and viewing characteristics, visual impacts would be Adverse and Significant, as indicated in Table 2-2.

Adverse Visual Impacts. In the vicinity of KOP-South-7, implementation of the Project would result in adverse and significant visual impacts V-1, V-3, and V-5, as detailed in Table 6-1.

Mitigation Measures. Implementation of Mitigation Measures (MMs) would reduce these visual impacts to less than significant levels (Class II). MMs would include: V-1 – Clean up staging areas, storage areas, marshalling yards, access and spur roads, and structure locations on a regular periodic basis; V-2a – Use tubular steel poles instead of lattice steel towers in designated areas; V-2b – Treat surfaces with appropriate colors, textures, and finishes; V-4b – Slope-round and re-contour in areas as prescribed; and V-4d – Dispose of excavated materials as prescribed. **Special Note:** Both the new TRTP structures and the relocated existing transmission line structures should be tubular steel poles because of their visual prominence and position on the skyline.

Figure 3.14-42b
Visual Simulation
for KOP- South-7
Buddhist Columbarium at
Rose Hills Memorial Park
(Alternative 2, Segment 8)
Source: SCE, 2007.