







**COTTONWIND\***  
 \*Currently undergoing environmental review by the County of Kern in conjunction with a proposed wind farm development.

- 2 parallel approximately 4-mile single-circuit 220-kV T/Ls.
- Parallel and east of Antelope-Magunden No.1 220-kV T/L.


**Legend**

-  New single-circuit 500 kV
-  New single-circuit 220 kV
-  Replacement of 220 kV with single-circuit 500 kV
-  Replacement of 220 kV with double-circuit 500 kV
-  New right-of-way
-  Substation

Construct approximately 17 miles of new single-circuit 500-kV T/L.

- Construct approximately 16 miles of new single-circuit 500-kV T/L.
- Parallel and west of the existing ROW of the Midway-Vincent No. 3 500-kV T/L.

Note: These maps display only SCE's proposed Project. Alternatives are not shown.



Scale: 1" = 6,000'  
 Date: December 5, 2008  
 File: 1243\_Routemap5.dwg

