

Note: These maps display only SCE's proposed Project. Alternatives are not shown.

**Legend**

- New single-circuit 500 kV
- New single-circuit 220 kV
- Replacement of 220 kV with single-circuit 500 kV
- Replacement of 220 kV with double-circuit 500 kV
- New right-of-way
- Substation
- Use existing single-circuit 500 kV

Remove Eagle Rock-Pardee 220-kV T/L (~15 miles) and replace with new single-circuit 500-kV T/L (initially energized at 220 kV).

- Remove Antelope-Mesa 220-kV T/L and build new single-circuit 500-kV T/L (initially energized at 220 kV).
- The other new single-circuit 500-kV T/L connects into existing Rio Hondo-Vincent No. 2 220-kV T/L, which is currently constructed to 500-kV standards with 500-kV structures.

Expand existing ROW by approximately 250 feet on the west side to accommodate conductor swing under wind-loading conditions for the proposed T/L along the ~3 miles north of Gould Substation.

