

**PACIFIC GAS AND ELECTRIC COMPANY  
San Bruno GT Line Rupture Investigation  
Data Response**

PG&E Data Request No.:	CPUC_203-03		
PG&E File Name:	SanBrunoGT-LineRuptureInvestigation_DR_CPUC_203-Q03		
Request Date:	October 10, 2011	Requester DR No.:	
Date Sent:	October 20, 2011	Requesting Party:	CPUC (CPSD)
		Requester:	Aimee Cauquiran

**QUESTION 3**

Total number of existing distribution leaks.

**ANSWER 3**

The following are the number of existing distribution leaks as of October 12, 2011

<b>Distribution Leaks</b>	
<b>Grade</b>	<b>Number</b>
1	12
2+	855
2	7675
3	42689