


**Consumer Confidence Report
Certification Form**
(To be submitted with a copy of the CCR)

Water System Name: Goldside/Hillview : Hillview Water Company, Inc.

Water System Number: 201-0014

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 07-01-13 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the California Department of Public Health.

Certified by: Name: James F. Foster
Signature: 
Title: Manager
Phone Number: (559) 683-4322 Date: 7-01-13

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - Posting the CCR at the following URL: www.h2oakhurst.com
 - Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - Advertising the availability of the CCR in news media (attach copy of press release)
 - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - Posted the CCR in public places (attach a list of locations)
 - Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
 - Delivery to community organizations (attach a list of organizations)
 - Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
 - Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
 - Other (attach a list of other methods used)
- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following URL: www._____
- For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: http://h2oakhurst.com/downloads/_CCRGoldside_12.pdf
- Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www._____
- Water system emailed the CCR as an electronic file email attachment.
- Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- Requires prior CDPH review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

Each Customer was mailed a one page notice (attached) with the direct URL for their CCR's. Any customer that requested a hard copy by phone, in writing or in person was mailed the entire CCR by US mail or able to pick one up at the customer counter at Hillview Water Company offices.

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.



June 29, 2013

To: Hillview Goldside Customer

Regarding: The 2012 Consumer Confidence Report (CCR)

In **2012**, Hillview Water Company, Inc. detected **26** contaminants in the drinking water and **4** of them were above the EPA accepted level for drinking water. Please go to:

http://h2oakhurst.com/downloads/_CCRGoldside_12.pdf

to view 2012 annual water quality report and learn more about your drinking water. This report contains important information about the source and quality of your drinking water. For a translation of the water quality report or to speak with someone about the report please call **559-683-4322**. If you would like a paper copy of the **2012** Annual Water Quality Report mailed to your home, please call **559-683-4322**.

Spanish Translation:

Durante el año 2012 Hillview Water Company, Inc. detectó 26 contaminantes regulados en el agua potable. 4 de los contaminantes detectados en el agua potable reflejaron niveles que exceden los límites legales establecidos por la EPA.

Para acceder al más reciente reporte anual de calidad de agua y para más información acerca de su agua potable puede visitar :

http://h2oakhurst.com/downloads/_CCRGoldside_12.pdf

*El reporte anual contiene valiosa información acerca de las fuentes de abasto y calidad de su agua potable. Para obtener una traducción del reporte de calidad de agua o para preguntas acerca del reporte por favor comuníquese al **559-683-4322**. Si desea obtener por correo una copia de su más reciente reporte de calidad de agua puede solicitar la misma llamando al **559-683-4322**.*

Hillview Water Company, Inc.

2012 Consumer Confidence Report

Water System Name: Goldside/Hillview

Report Date: 6/28/2013

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2012 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Hard rock wells, which draw from underground aquifers.

Name & location of source(s): Hillview Estates – Well #1, Goldside – Well #2, Well #4, Well #6, Well #7, River Creek – Well #1 and Well #2 & Miami Creek #1.

Drinking Water Source Assessment information: A source water assessment was conducted for the active water supply wells of the Hillview Water Co. – Goldside by Department of Health services on August 20, 2002. The sources considered most vulnerable to the following activities not associated with any detected contaminants: Wells – Water supply, septic system – low density, sewer collection systems. A copy of the complete assessment may be viewed at: Hillview Water Co. – Goldside, 40312 Greenwood Way, Oakhurst, CA 93644. You may request a summary of the assessment be sent to you by contacting: Mr. James Foster (559)683-4322, P.O. Box 2269, Oakhurst, CA 93644

Time and place of regularly scheduled board meetings for public participation: Do not schedule meetings at regular intervals. Public is allowed to participate in all CPUC proceedings.

For more information, contact: Hillview Water Co., Inc.

Phone: (559) 683-4322

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA						
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria	
Total Coliform Bacteria	(In a mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment	
Fecal Coliform or <i>E. coli</i>	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste	
TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in the last sample set)	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	10	7.8	None	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	10	.123	None	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent	Sample	Level	Range of	MCL	PHG	Typical Source of Contaminant

(and reporting units)	Date	Detected	Detections		(MCLG)	
Sodium (ppm)	9/12	180	14-180	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	9/12	320	260-320	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Gross Alpha Activity – pCi/L	9/12	11.6	11.6	15	(0)	Erosion of natural deposits
Arsenic - ppb	9/12	2.4	ND-2.4	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Chromium – ppb	5/12	ND	ND-8.0	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride – ppm	9/12	.43	.41-.43	2.0	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nickel - ppb	9/12	ND	0-13	100	12	Erosion of natural deposits; discharge from metal factories
Nitrate (as nitrate, NO ₃) ppm	9/12	22	0-22	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
TTHMs (Total Trihalomethanes) ppb	5/12	.95	0-4.5	60	N/A	By-product of drinking water disinfection
Toluene - ppb	9/12	.55	ND-.55	150	150	Discharge from petroleum and chemical factories; underground gas tank leaks
*Uranium – pCi/L	7/12	56	1.4-56	20	0.43	Erosion of natural deposits
Selenium – ppb	9/09	3.2	ND-3.2	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
1,2-Dichlorobenzene - ppb	5/12	5.9	ND-5.9	600	0.06	Discharge from factories, dry cleaners, and auto shops (metal degreaser)
Chlorine - ppm	Jan - Dec	1.0	0.4-1.0	[4.0]	[4]	Drinking water disinfectant added for treatment

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
--	-------------	----------------	---------------------	-----	------------	-------------------------------

Chloride - ppm	9/12	430	340-430	500	N/A	Runoff/leaching from natural deposits; industrial wastes
Color - Units	9/12	5.0	5.0	15	N/A	Naturally-occurring organic materials
Copper - ppm	5/12	.045	ND-.045	1.0	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
*Iron - ppb	5/12	2000	0-2000	300	N/A	Leaching from natural deposits; industrial wastes
*Manganese - ppb	10/12	89	ND-89	50	N/A	Leaching from natural deposits
* Specific Conductance µS/cm	9/12	1700	240-1700	1600	N/A	Substances that form ions when in water; seawater influence
Sulfate - ppm	9/12	28	23-28	500	N/A	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (TDS) - ppm	9/12	1000	850-1000	1000	N/A	Runoff/leaching from natural deposits
Turbidity - Units	11/11	<1.0	ND-2.1	5	N/A	Soil runoff
Zinc - ppm	5/12	.140	0-.14	5.0	N/A	Runoff/leaching from natural deposits; industrial wastes

TABLE 6 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hillview Water Company, inc. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Hillview Water Company has received a Proposition 84 grant from the California Department of Public Health. The SAFE DRINKING WATER, WATER QUALITY AND SUPPLY, FLOOD CONTROL, RIVER AND COASTAL PROTECTION BOND ACT OF 2006 grant is providing a new, increased capacity, arsenic, iron & manganese removal treatment plant in Oakhurst. The current Iron & Manganese removal Plant in Sierra Lakes will be moved to the Goldside. Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect health at the MCL levels.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
*Uranium - pCi/L	Erosion of natural deposits	N/A	Well Was taken Off line and will only be used for Emergency Standby.	Some people who drink water containing uranium in excess of the MCL over many years may have kidney problems or an increased risk of getting cancer.
* Iron (a) - ppb	Leaching from natural deposits; industrial wastes	Until the current Sierra Lakes Green Sand Iron & Manganese filter is move to Goldside.	Hillview has received a Proposition 84 grant from the California Department of Public Health which will allow the transfer of Iron & Manganese Removal System to Goldside. Completion is expected in 2014.	(a) The Iron MCL is a secondary drinking water standard and no Health Effects Language is provided.
*Manganese (a) - ppb	Leaching from natural deposits	None. The well can not pump directly into distribution.	Hillview has received a Proposition 50/84 grants from the California Department of Public Health to provide new additional treatment. The projects are in progress. Completion expected in 2014.	(a) The Manganese MCL is a secondary drinking water standard and no Health Effects Language is not provided for the MCL of 50ppb, only for the notification level of 500ppb.
* Specific Conductance (a) $\mu\text{S}/\text{cm}$	Substances that form ions when in water; seawater influence	N/A	None. The well does not feed directly into distribution. Blending will continue.	(a) Specific Conductance MCL is a secondary drinking water standard and no Health Effects Language is provided.

- (a) There are no PHGs, MCLGs, or mandatory standard health effects language for these constituents because secondary MCLs are set on the basis of aesthetics.

For Water Systems Providing Ground Water as a Source of Drinking Water

**TABLE 7 – SAMPLING RESULTS SHOWING
FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES**

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0		0	(0)	Human and animal fecal waste
Enterococci	0		TT	n/a	Human and animal fecal waste
Coliphage	0		TT	n/a	Human and animal fecal waste