

CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

For the year 2012

Water System Name: R.R. Lewis Small Water Co.

Water System Number: 4600017

The water system named above hereby certifies that its Consumer Confidence Report has been distributed to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Health Services.

Certified by: Name LARRY OSTROM
Title OWNER
Phone Number (209) 948-8817 Date 5/31/2013

Water systems are not required to report the following information, but may do so by checking all items that apply:

- CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: ALL CURRENT CUSTOMERS BY MAIL WITH JUNE BILLING 5/31
- "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
- Posted the CCR ~~on the Internet at www.~~ @ LOCAL POST OFFICE
 - Mailed the CCR to postal patrons within the service area (attach zip codes used)
 - Advertised the availability of the CCR in news media (attach copy of press release)
 - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published).
 - Posted the CCR in public places (attach a list of locations)
 - Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
 - Delivery to community organizations (attach a list of organizations)
- [For systems serving at least 100,000 persons] Posted CCR on a publicly-accessible internet site at the following address: www. _____
- [For investor-owned utilities] Delivered the CCR to the California Public Utilities Commission
- COPY TO DEPT OF HEALTH, REDDING.

R.R. Lewis Small Water Company 2012 WATER QUALITY CONSUMER CONFIDENCE REPORT

This report shows our water quality and what it means. For additional information concerning your drinking water, contact Larry Ostrom at (800)446-6225.

Water for the site comes from a spring (Anderson). Due to inconsistencies in the Wixson spring water, Wixson source is not used. All water furnished came from Anderson Spring.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Definitions of Terms

In this report you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are established by the federal Environmental Protection Agency (USEPA).

Public Health Goal or PHG - The level of a contaminant in drinking water below which there is no known or expected risk to health. PHG's are set by the California Environmental Protection Agency.

Primary Drinking Water Standard - MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Regulatory Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique - A required process intended to reduce the level of a contaminant in drinking water.

Water Testing Results

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. The term "contaminant," as used below refers to any substance in water, other than pure water itself that is regulated and monitored for health or aesthetic reasons.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.
- If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. RR Lewis Small Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

In order to ensure that tap water is safe to drink, the USEPA and the State Department of Public Health (Department)

prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly individuals, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers and/or the Safe Drinking Water Hotline.

Detected Contaminants In Our Water

RR Lewis Small Water Company routinely monitors for contaminants in our drinking water according to Federal and State laws. The following paragraphs and tables show the results of our most recent testing. Please note that not all testing is required annually, so in some cases our results are more than one year old.

Microbiological Water Quality

Testing for bacteriological contaminants in the distribution system is required by State regulations. This testing is done regularly to verify that the water system is free from coliform bacteria. The minimum number of tests required per month for our water system is four. The highest number of samples found to contain coliform in any one month was ZERO.

Violation Information

RR Lewis Small Water Co. is pleased to report that there are no violations issued in 2012.

PUBLIC UTILITIES COMMISSION

505 VAN NESS AVENUE

SAN FRANCISCO, CA 94102-3298



July 24, 2013

To: All Water Utilities' that have yet to submit their Consumer Confidence Report (CCR) to the California Public Utilities Commission (Commission)

If you have not yet submitted a copy of your annual Consumer Confidence Report (CCR) to the Commission, please send it now. If you are posting your annual CCR on your website, please send a link via e-mail to mdc@cpuc.ca.gov to the website address where your CCR is posted.

The instructions for completing a CCR for Small Water Systems can be accessed at the California Department of Public Health (CDPH) website at <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/CCR.aspx>. If you need assistance preparing your CCR, please contact your Drinking Water Field Operations Branch (DWFOB) District Office or Local Primacy Agency (LPA).

Please submit a copy of your most recent CCR to the Commission's Division of Water and Audits at the address below. You also need to submit the Certification Form that is posted at the CDPH website at:

http://www.cdph.ca.gov/certlic/drinkingwater/Documents/CCR/CCR4SWSAttachment6CertificationForm_20100104.doc. This certification form is due to the Commission by October 1, 2013. The most recent CCR and the Certification Forms are to be mailed to:

California Public Utilities Commission
Division of Water and Audits
Attn: Ms. Carmen Rocha
505 Van Ness Avenue
San Francisco, CA 94102

If you believe that you had already submitted your Water Utility's CCR to our office or if you have any questions about the CCR, please contact Carmen Rocha of my staff, at 415.703.2162 or e-mail her at mdc@cpuc.ca.gov. If you still are not sure of what a CCR is or how a CCR form looks, the CCR 2009 Template can be accessed at the CDPH website's at: http://www.cdph.ca.gov/certlic/drinkingwater/Documents/CCR/CCR1SWSReportForm_20100104.doc

Sincerely,

A handwritten signature in black ink, appearing to read "Bruce DeBerry".

Bruce DeBerry,
Division of Water and Audits