


ATTACHMENT 7

Consumer Confidence Report Certification Form *(to be submitted with a copy of the CCR)*

Water System Name: Redwood Lodge Water Company

Water System Number: WTD439

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 3/22/2013 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the California Department of Public Health.

Certified by: Name: Dominic Massetti
Signature: 
Title: Agent for Owner Patricia Heimer
Phone Number: (408) 406-6315 Date: 3/22/2013

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: Email to service list on file

"Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

Posting the CCR on the Internet at www.

Mailing the CCR to postal patrons within the service area (attach zip codes used)

Advertising the availability of the CCR in news media (attach copy of press release)

Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)

Posted the CCR in public places (attach a list of locations)

Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools

Delivery to community organizations (attach a list of organizations)

Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.

For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.

2012 Consumer Confidence Report

Water System Name: Redwood Lodge Water Company Report Date: 3/22/2013

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2012 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Natural spring #1 – Underground collection – sealed storage

Name & location of source(s): Santa Cruz County APN 097-07-06
25127 Soquel-San Jose road, Los Gatos CA 95033

Drinking Water Source Assessment information: No Assessment has been completed

Time and place of regularly scheduled board meetings for public participation: _____
For water quality comments contact Patricia Heimer PO Box 320161, Los Gatos, CA 95032

For more information, contact: Patricia Heimer Phone: (408) 688-6711

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring

minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA						
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria	
Total Coliform Bacteria	(In a mo.)	0 See Attached	More than 1 sample in a month with a detection	0	Naturally present in the environment	
Fecal Coliform or <i>E. coli</i>	(In the year)	0 See Attached	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste	

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in the last sample set)	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	1	ND	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	1	ND	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	8/10/2010	18 mg/L		none	none	Salt present in the water and is generally naturally occurring

Hardness (ppm)	8/10/2010	160mg/L		none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring
----------------	-----------	---------	--	------	------	--

*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
See attached full spectrum test						

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
See attached full spectrum test						

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
See attached full spectrum test					

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Redwood lodge Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water disinfection is accomplished by adding 16 oz Chlorine based disinfectant to 2500 gallons of collected spring water. Dilution into 26,000 gallons of water occurs prior to delivery to customers. Residual Chlorine levels at the monitoring point on Timber Lodge Road are 0.21 mg/L and can be found on the attached quarterly water test reports.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language

For Water Systems Providing Ground Water as a Source of Drinking Water

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year)		0	(0)	Human and animal fecal waste
Enterococci	(In the year)		TT	n/a	Human and animal fecal waste
Coliphage	(In the year)		TT	n/a	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Ground Water Source Samples, Uncorrected Significant Deficiencies, or Ground Water TT

SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLE				
SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES				
VIOLATION OF GROUND WATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct	Health Effects

			the Violation	Language

For Systems Providing Surface Water as a Source of Drinking Water

TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES	
Treatment Technique ^(a) (Type of approved filtration technology used)	
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to ____ NTU in 95% of measurements in a month. 2 – Not exceed ____ NTU for more than eight consecutive hours. 3 – Not exceed ____ NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	
Highest single turbidity measurement during the year	
Number of violations of any surface water treatment requirements	

- (a) A required process intended to reduce the level of a contaminant in drinking water.
 - (b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.
- * Any violation of a TT is marked with an asterisk. Additional information regarding the violation is provided below.

Summary Information for Violation of a Surface Water TT

VIOLATION OF A SURFACE WATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language

Summary Information for Operating Under a Variance or Exemption

*****SERVICE LIST*****

REDWOOD LODGE WATER COMPANY

CPUC UTILITY NUMBER WTD439

LAST CHANGED: 3/22/2013

Water users:

Dave Bates	dmb@timanagementgroup.com	205 Timber Lodge Rd. Los Gatos, CA 95033
JR Call	call4jr@gmail.com	15930 Redwood Lodge Rd. Los Gatos, CA 95033
Linda Cody	lcody@earthlink.net	15955 Redwood Lodge Rd. Los Gatos, CA 95033
Roger Connelly	rconnelly@apple.com	155 Timber Lodge Rd. Los Gatos, CA 95033
Michael Grassof	mikegrassbuild@aol.com	251 Timber Lodge Rd. Los Gatos, CA 95033
Kent Harper	sharperest27@aol.com	15953 Redwood Lodge Rd. Los Gatos, CA 95033
Scott Harris	portola@gmail.com	135 Timber Lodge Rd. Los Gatos, CA 95033
Patricia Heimer	rlwcpat@gmail.com	PO Box 320161 Los Gatos CA 95032
Paul Mlyniec	paul@dartforms.com	25135 Soquel-San Jose Rd. Los Gatos, CA 95033
Frank Roeth	frankroeth@live.com	PO Box 1793 Soquel, CA 95073
Hanh Trang	hanhtrang1000@yahoo.com	25080 Soquel-San Jose Rd. Los Gatos, CA 95033
Carly Van Leeuwen	hockygod@me.com	25070 Soquel-San Jose Rd. Los Gatos, CA 95033
Daniel Reid Clark	gottagoreid@netzero.com	PO Box 403 Redwood Estates, CA 95044

Related parties:

Terri Smith	terimacsmith@gmail.com	141 Carlow Ct. Sunnyvale, CA 94087
Dominic Massetti	nick@nmassetticonsulting.com	PO Box 8691 San Jose CA 95155-8691
Tyler Boswell	tyler@ferntreedesign.com	P.O. Box 600 Redwood Estates, CA 95044

California Department of Health

Troy Boone	ENV065@co.santa-cruz.ca.us	County of Santa Cruz, EHS
------------	--	---------------------------

CPUC Division of Water and Audits

505 Van Ness Ave. San Francisco, CA 94102

Miller, Michael	michael.miller@cpuc.ca.gov
Sustaita, Darlene	darlene.sustaita@cpuc.ca.gov

SOIL CONTROL LAB

42 HANGAR WAY
WATSONVILLE
CALIFORNIA
95076
USA

Redwood Lodge Water Co.
P.O. Box 320161
Los Gatos, CA 95032
Attn: Patricia Heimer

Work Order #: 2060416
Reporting Date: June 14, 2012

Bacteriological Examination of Water for Coliform Organisms

Date Received: Water sample(s) received June 13, 2012
Project # / Name: None / None
Water System #/Name: 4400584 REDWOOD LODGE WATER COMPANY (SSWS)
Sampling Type: Routine Sampling Period: June 2012
Sampler's Name: Tyler Boswell / AWSM
Matrix: Water

<u>Sample Identification</u>	<u>Sampling Date</u>	<u>Sampling Time</u>	<u>Residual Chlorine (mg/L)</u>	<u>Total Coliforms</u>	<u>E. coli</u>
25121 Timberlodge Rd.	06/13/12	11:53	0.21	Absent	Absent

Date/Time Analyzed: 06/13/12 16:45
Method of Analysis: SM 9223 B

CA ELAP Certificate #1494 (This identifies our Laboratory to the Health Department)

Mike Galloway

SOIL CONTROL LAB

42 HANGAR WAY
WATSONVILLE
CALIFORNIA
95076
USA

Redwood Lodge Water Co.
P.O. Box 320161
Los Gatos, CA 95032
Attn: Patricia Heimer

Work Order #: 2090483
Reporting Date: September 19, 2012

Bacteriological Examination of Water for Coliform Organisms

Date Received: Water sample(s) received September 18, 2012
Project # / Name: None / None
Water System #/Name: 4400584 REDWOOD LODGE WATER COMPANY (SSWS)
Sampling Type: Routine Sampling Period: September 2012
Sampler's Name: Tyler Boswell / AWSM
Matrix: Water

<u>Sample Identification</u>	<u>Sampling Date</u>	<u>Sampling Time</u>	<u>Residual Chlorine (mg/L)</u>	<u>Total Coliforms</u>	<u>E. coli</u>
25121 Timberlodge Rd.	09/18/12	09:18	0.21	Absent	Absent

Date/Time Analyzed: 09/18/12 17:00
Method of Analysis: SM 9223 B

CA ELAP Certificate #1494 (This identifies our Laboratory to the Health Department)

Mike Galloway

SOIL CONTROL LAB

42 HANGAR WAY
WATSONVILLE
CALIFORNIA
95076
USA

Redwood Lodge Water Co.
P.O. Box 320161
Los Gatos, CA 95032
Attn: Patricia Heimer

Work Order #: 2120303
Reporting Date: December 12, 2012

Bacteriological Examination of Water for Coliform Organisms

Date Received: Water sample(s) received December 11, 2012
Project # / Name: None / None
Water System #/Name: 4400584 REDWOOD LODGE WATER COMPANY (SSWS)
Sampling Type: Routine Sampling Period: December 2012
Sampler's Name: Tyler Boswell / AWSM
Matrix: Water

<u>Sample Identification</u>	<u>Sampling Date</u>	<u>Sampling Time</u>	<u>Residual Chlorine (mg/L)</u>	<u>Total Coliforms</u>	<u>E. coli</u>
25121 Timberlodge Rd.	12/11/12	10:21	0.23	Absent	Absent

Date/Time Analyzed: 12/11/12 17:00
Method of Analysis: SM 9223 B

CA ELAP Certificate #1494 (This identifies our Laboratory to the Health Department)

Mike Galloway

SOIL CONTROL LAB

42 HANGAR WAY
WATSONVILLE
CALIFORNIA
95076
USA

Redwood Lodge Water Co.
P.O. Box 320161
Los Gatos, CA 95032
Attn: Patricia Heimer

Work Order #: 3030032
Reporting Date: March 2, 2013

Bacteriological Examination of Water for Coliform Organisms

Date Received: Water sample(s) received March 01, 2013
Project # / Name: None / None
Water System #/Name: 4400584 REDWOOD LODGE WATER COMPANY (SSWS)
Sampling Type: Routine Sampling Period: March 2013
Sampler's Name: Tyler Boswell / AWSM
Matrix: Water

<u>Sample Identification</u>	<u>Sampling Date</u>	<u>Sampling Time</u>	<u>Residual Chlorine (mg/L)</u>	<u>Total Coliforms</u>	<u>E. coli</u>
25121 Timberlodge Rd.	03/01/13	14:48	0.21	Absent	Absent
15955 Redwood Lodge Road (private tank)	03/01/13	14:58	N/D	Absent	Absent

Date/Time Analyzed: 03/01/13 17:15
Method of Analysis: SM 9223 B

CA ELAP Certificate #1494 (This identifies our Laboratory to the Health Department)

Mike Gallows

SOIL CONTROL LAB

42 HANGAR WAY
WATSONVILLE
CALIFORNIA
95076
USA

Redwood Lodge Water Co.
P.O. Box 320161
Los Gatos, CA 95032
Attn: Patricia Heimer

Work Order #: 0080245
Reporting Date: August 29, 2010

Date Received: August 10, 2010
Project # / Name: None / None
Water System #: 4400584 REDWOOD LODGE WATER COMPANY (SSWS)
Sample Identification: Water Sample, sampled 8/9/2010 5:30:00PM
Sampler Name / Co.: D. Massetti / Redwood Lodge Water Co.
Matrix: Water
Laboratory #: 0080245-01

	Results	Units	RL	State Drinking Water Limits 1	Analysis Method	Date Analyzed	Flags
General Mineral							
pH	6.5	pH Units	0.1	-	EPA 150.1	08/10/10	
Specific Conductance (EC)	410	uS/cm	1.0	1600	SM2510B	08/10/10	
Hydroxide as OH	ND	mg/L	2.0	-	SM 2320B	08/10/10	
Carbonate as CO3	ND	mg/L	2.0	-	SM 2320B	08/10/10	
Bicarbonate as HCO3	170	mg/L	2.0	-	SM 2320B	08/10/10	
Total Alkalinity as CaCO3	140	mg/L	2.0	-	SM 2320B	08/10/10	
Hardness	160	mg/L	5.0	-	SM 2340 B	08/13/10	
Total Dissolved Solids	250	mg/L	10	1000	SM2540C	08/11/10	
Nitrate as NO3	3.6	mg/L	1.0	45	EPA 300.0	08/11/10	
Chloride	14	mg/L	1.0	500	EPA 300.0	08/11/10	
Sulfate as SO4	42	mg/L	1.0	500	EPA 300.0	08/11/10	
Fluoride	0.22	mg/L	0.10	2	EPA 300.0	08/11/10	
Calcium	43	mg/L	0.50	-	EPA 200.7	08/13/10	
Magnesium	13	mg/L	0.50	-	EPA 200.7	08/13/10	
Potassium	1.5	mg/L	0.50	-	EPA 200.7	08/13/10	
Sodium	18	mg/L	5.0	-	EPA 200.7	08/13/10	
Iron	ND	ug/L	50	300	EPA 200.7	08/13/10	
Manganese	ND	ug/L	20	50	EPA 200.7	08/13/10	
Copper	ND	ug/L	50	1000	EPA 200.7	08/13/10	
Zinc	ND	ug/L	50	5000	EPA 200.7	08/13/10	
Inorganics							
Nitrate/Nitrite as N	0.81	mg/L	0.10	10	EPA 300.0	08/11/10	
Arsenic	ND	ug/L	2.0	10	EPA 200.8	08/13/10	
Barium	ND	ug/L	100	1000	EPA 200.7	08/13/10	

RL - are levels down to which we can quantify with reliability, a result below this level is reported as "ND" for Not Detected.

State Drinking Water Limits₁ - as listed by California Administrative Code, Title 22.

* - a * in the left hand margin of the report means that particular constituent is above the California Drinking Water Limits.

Mike Galloway

SOIL CONTROL LAB

42 HANGAR WAY
WATSONVILLE
CALIFORNIA
95076
USA

Redwood Lodge Water Co.
P.O. Box 320161
Los Gatos, CA 95032
Attn: Patricia Heimer

Work Order #: 0080245
Reporting Date: August 29, 2010

Date Received: August 10, 2010
Project # / Name: None / None
Water System #: 4400584 REDWOOD LODGE WATER COMPANY (SSWS)
Sample Identification: Water Sample, sampled 8/9/2010 5:30:00PM
Sampler Name / Co.: D. Massetti / Redwood Lodge Water Co.
Matrix: Water
Laboratory #: 0080245-01

	Results	Units	RL	State Drinking Water Limits 1	Analysis Method	Date Analyzed	Flags
Inorganics							
Boron	ND	ug/L	100	-	EPA 200.7	08/13/10	
Cadmium	ND	ug/L	1.0	5	EPA 200.8	08/13/10	
Chromium	ND	ug/L	1.0	50	EPA 200.8	08/13/10	
Cyanide (total)	ND	ug/L	100	200	SM 4500-CN F	08/23/10	
Lead	ND	ug/L	5.0	-	EPA 200.8	08/13/10	
Mercury	ND	ug/L	1.0	2	EPA 245.1	08/16/10	
Selenium	ND	ug/L	5.0	50	EPA 200.8	08/13/10	
Silver	ND	ug/L	10	100	EPA 200.7	08/13/10	
MBAS (Surfactants)	ND	mg/L	0.025	0.5	SM5540C	08/10/10	
Aluminum	ND	ug/L	50	1000	EPA 200.7	08/13/10	
Antimony	ND	ug/L	6.0	6	EPA 200.8	08/13/10	
Beryllium	ND	ug/L	1.0	4	EPA 200.7	08/13/10	
Nickel	ND	ug/L	10	100	EPA 200.7	08/13/10	
Thallium	ND	ug/L	1.0	2	EPA 200.8	08/13/10	
Nitrite as N	ND	mg/L	0.10	1	EPA 300.0	08/11/10	
General Physical							
Color	ND	Color Units	3.0	-	SM 2120E	08/10/10	
Threshold Odor No.	ND	T.O.N.	1.0	-	EPA 140.1	08/10/10	
Turbidity	0.50	NTU	0.10	-	SM 2130B	08/10/10	

RL - are levels down to which we can quantify with reliability, a result below this level is reported as "ND" for Not Detected.

State Drinking Water Limits, - as listed by California Administrative Code, Title 22.

* - a * in the left hand margin of the report means that particular constituent is above the California Drinking Water Limits.

Mike Galloway